



- NOTES THIS SHEET**
- ① CONNECT NEW EXIT SIGN TO EXISTING CIRCUIT SERVING EXIT SIGN BEING REMOVED.
 - ② ALL CIRCUITS FOR THIS UNIT PANEL 3P4 FOR THIRD FLOOR. SEE PANEL SCHEDULES 4P4, 5P4, 6P4 & 7P4 FOR CIRCUIT NUMBERS FOR EACH RESPECTIVE FLOOR.
 - ③ ALL CIRCUITS FOR THIS UNIT PANEL 3P5 FOR THIRD FLOOR. SEE PANEL SCHEDULES 4P5, 5P5, 6P5 & 7P5 FOR CIRCUIT NUMBERS FOR EACH RESPECTIVE FLOOR.
 - ④ EXTEND EXISTING LIGHTING CIRCUIT IN 1" ST TO NEW FIXTURE AND CONNECT COMPLETE.

CITY OF SEATTLE
DEPT. OF CONSTRUCTION
AND LAND USE
JAN 25 1999

990106-034

Passway lighting?

EXIT SIGNS & ILLUMINATION
SHALL COMPLY WITH
APPROVED BUILDING PLANS

ELECTRICAL INSTALLATIONS
WILL COMPLY WITH THE
REQUIREMENTS OF THE
N.E.C. CODE SEC. 780-12 (C)

Tonkin/Hoynes/Lokan
Architecture and Urban Design

204 First Avenue South, Seattle, Washington 98104
PHONE: (206) 624-7860 / FAX: (206) 622-1796



FRYE HOTEL
223 YESLER WAY, SEATTLE, WA
LOW INCOME HOUSING INSTITUTE
SEATTLE, WASHINGTON

DRAWING ISSUE	PERMIT SET
6/5/98	BID SET
1/22/98	BID SET
1/28/98	BID SET

DRAWING TITLE
**3RD-7TH FLOOR
LIGHTING PLAN**

SCALE: 1/8" = 1'-0"
PLOT DATE: 7/28/98
CADD FILE: 801E231
PROJ. MGR.: C.M.
DRAFTER: GUB

SHEET NO.

E231

BID SET

3RD-7TH FLOOR LIGHTING PLAN
SCALE: 1/8" = 1'-0"
NORTH

PATH ENGINEERING INC.
17328 BOTHELL EVERETT HWY SE, SUITE H
BOTHELL, WASHINGTON 98012
(425) 481-7735 FAX (425) 481-7692
CONTACT: CARL J. MACIHL
JOB NUMBER: 8017

